CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1062:112 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Detection Systems, Inc., 130 Perinton Parkway, Fairport, NY 14450

Contact: Frank Mioduszewski (585) 223-4060 Fax (585) 421-4263

DESIGN: Models DIS-240 remote test/indicator and DIS2000 remote indicator. *Models SMK-RA5 and

*SMK-RA12/24 remote annunciators. Refer to listee's data sheet for additional detailed product

description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as accessories for use with listee's separately listed detection devices. Models DIS-240

and DIS2000 for use with listee's separately listed Models DS-240 and DS-241 (CSFM Listing No.

7260-1062:106) beam smoke detection system.

*Model SMK-RA5 for use with listee's separately listed Models MB2W, MB4W, MB4WA, MB4WE, MB4WS (CSFM Listing No. 7300-1062:107) smoke detector bases and *Models DS290 (CSFM Listing No. 3240-1062:136), *DS291, *DS292, and *DS293 (CSFM Listing No.

3240-1062:134) duct smoke detector housings.

*Model SMK-RA12/24 for use with listee's separately listed Model MXB2W (CSFM Listing No. 7300-1062:131) smoke detector base. Refer to listee's Installation Instructions Manual for

details.

Rev. 04-02-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

JUNE 21, 2003 Date Issued: Listing Expires June 30, 2004

DIANE K. AREND, Senior Deputy Authorized By:

Program Manager